



QUALITY CERTIFICATE

Vessel SHORE TANK NO. 3
Customer SPRAGUE
Operation ANALYSIS

Port SEARSPORT, MAINE Date July 8, 2005

Report SP/05/0709
Reference V-05-01020

Terminal

SPRAGUE

Sample # 326739

Name of material being tested Description of sample source Samples Drawn by (company) Samples Tested by (company)

NO. 6 FUEL OIL 2.0%

EX. SHORE TANK NO. 3 AFTER DISCHARGE OF B NO. 215
BSI-INSPECTORATE
BSI-INSPECTORATE

Tests being Performed	Test method	Minimum	Maximum	Sample Source
				· · · · · · · · · · · · · · · · · · ·
GRAVITY, API @ 60 F FLASH POINT, F VISCOSITY, SSF @ 122 F POUR POINT, F WATER & SEDIMENT, % VOL. SULPHUR, % WT. 'H, % WT. VANADIUM, PPM SODIUM, PPM BTU'S/POUND BTU'S/GALLON NITROGEN, % WT. CARBON RESIDUE, % WT. ASPHALTENES, % WT.	ASTM D 4052 ASTM D 93 ASTM D 445/2161 ASTM D 97 ASTM D 1796 ASTM D 4294 ASTM D 482 AA/AE AA/AE CALCULATION CONVERSION ASTM D 5762 ASTM D 4530 IP-143			10.2 195 247 +26.6 0.05 1.90 0.040 78 10 18,258 151,834 0.1852 13.22 3.6
SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS REPRESENTING THE SPECIFICATIONS OF THE PRODUCT AT THE SPRAGUE TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE. THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF ESTABLISHING THE INDEPENDENTLY VERIFIED PRODUCT SPECIFICATION ON A COMPOSITE BASIS IN SPRAGUE'S TERMINAL SHORE TANK AS NOTED ON THE CERTIFICATE. THE INSPECTION REPORT IS NOT TO BE USED FOR ANY OTHER PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR THE PRODUCT AFTER DELIVERY BY SPRAGUE TO CUSTOMER. SPRAGUE DISCLAIMS ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR AN INTENDED USE EXCEPT AS MAY BE SPECIFICALLY SET FORTH IN WRITING IN ANY CONTRACT OR TERMS OF SALE BETWEEN SPRAGUE AND A BUYER OF PRODUCT. SPRAGUE ASSUMES NO LIABILITY FOR CLAIMS OR LOSSES THAT MAY ARISE FROM CUSTOMER'S USE OF THIS INSPECTION REPORT/ANALYSIS.				

DENNIS E. CURTIS

Inspectorate America Corp (Searsport, Me.)